CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0992:115 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Napco, 333 Bayview Ave., Amityville NY 11701

Contact: *Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

MAGNUM ALERT 3000 and SIGNATURE 5500 series. Refer to listee's data sheet for detailed **DESIGN**:

product description and operational considerations.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories

shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as a household control unit when used with separately listed compatible initiating

devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for

details.

NOTE: Burglary and other non-fire functions were not examined.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 21, 2004 Listing Expires June 30, 2005

DIANE K. AREND. Senior Deputy Authorized By:

Program Manager